

HOLCIM DUQUESNE SLAG

AIR COOLED BLAST FURNACE SLAG

#8 Gradation
Test Results

#8 Quality Statistical Summary Report		
Period	01/01/2023 - 05/08/2023	
Sieve/Test	Average	Specification
1/2" (12.5mm)	100.0	100-100
3/8" (9.5mm)	96.1	85-100
1/4" (6.3mm)	54.0	
#4 (4.75mm)	23.8	10-30
#8 (2.36mm)	3.6	0-10
#16 (1.18mm)	2.4	0-5
Pan	0.00	

In the United States, Holcim is the leader in innovative and sustainable building solutions. Our customers rely on us to help them design and build better communities that deliver structural integrity and eco-efficiency.

Duquesne Slag Operations
890 Noble Drive
West Mifflin, PA 15122
Tel.: 412-461-1163
www.holcim.us

